



4.1 Testing and Maintenance

At least once per year, each Customer Shall have a certified test conducted on The Backflow Prevention Device on each of its Water Services and deliver the certificate and results of the test to the District. In those specific instances where the District deems the Hazard to be great enough, certified inspections and/or tests may be required more than once per year.

As necessary or required, the Customer's Backflow Prevention Device(s) shall be repaired or replaced at the expense of the Customer whenever the device s found to be defective. Records of all such tests, repairs or replacements shall be kept by Customer, a copy of which shall be submitted to the District.

All testing gauges used in the District Water System shall be checked yearly for accuracy.

The District retains the right to test or otherwise check the installation and operation of any Backflow Prevention device(s) at any time to assure proper operation.

4.2 Compliance

Failure of the Customer to cooperate in the installation, maintenance, testing or inspection of the Backflow Prevention Devices shall be considered a violation of the Rules and Regulations and therefore subject to Violator's Liability.

Service of water to a Customer may be revoked per Article I, Discontinuance or Revocation of Service, if actual or potential Cross-Connection is found to exist on a Customer's property. Service may also be revoked when any defect is found in an installed Backflow Prevention Device, or if a Backflow Prevention Device has been removed or by-passed. Reinstatement of service is subject to Article I, Reinstatement of Service.